

No. C.21.2112.0148



Verification of Conformity

Applicant:	ACREL CO., LTD. NO.253, YULV ROAD, JIADING, SHANGHAI, CHINA
Manufacturer	JIANGSU ACREL ELECTRICAL MANUFACTURING. CO., LTD. NO.5, DONGMENG ROAD, NANZHA STREET, JIANGYIN CITY, JIANGSU PROVINCE
Product description	Energy Meter (DIN-RAIL MOUNTED)
Model No.	ADL400 ADL200
Model May Cover	/
Parameter	/
Test report	8621.SH.2112.0148, 2022-01-13
Test standard	IEC 62052-11:2003 Electricity metering equipment (a.c.) — General requirements, tests and test conditions-Part 11: Metering equipment IEC 62053-22:2003 Electricity metering equipment (a.c.) — Particular requirements — Part 22:Static meters for active energy(classes 0.2S and 0.5S)
Conclusion:	This kind of rack mounted meters were not done the dustproof and waterproof test.The meters should be installed in a closed enclosure not less than IP51 or IP54 protection level when they used.
Date	January 14, 2022

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements.

The CE marking as shown below can be affixed on the product after preparation of necessary technical documentation.

Other relevant Directives have to be observed.

For and on behalf of
TUV Thuringen (Shanghai) Co., Ltd.

TUV THURINGEN (SHANGHAI) CO., LTD.
ROOM C6, FLOOR 16TH JIANGSU BUILDING, NO.526 LAOSHAN ROAD, SHANGHAI 200122, P.R.CHINA
E-mail: shanghai@tuv-thuringen.com.cn website: <http://www.tuv-thuringen.com.cn> www.tuev-thueringen.de
Copyright of this verification of conformity is owned by TUV THURINGEN (SHANGHAI) CO., LTD. And may not be reproduced other than in full and with the prior approval of the general manager.