

# CERTIFICATE

**Anbotek**  
Product Safety

## Certificate of Conformity

Electromagnetic Compatibility Regulations 2016 by UK legislation

(UK SI 2016 No. 1091)

Registration No.: **AT78251EC206345**

Report No.: **78251EC20634501**

**Applicant** : **Acrel Co., Ltd.**  
No.253, Yulv Road, Jiading District, Shanghai, China

**Product Identification** : **Electricity Meter**  
**Model No.** : **AGF-AE-D, AGF-AE-D/200, AGF-AE-D/100, AGF-AE-S, DSS3366-TD-A**

**Trade Mark** : **Acrel**

**Rating** : **Measuring Voltage input:AC 208V/240V;  
Measuring Current input:AC0...200A;  
Freq:60Hz**

**Test Standards** : **BS EN IEC 61326-1: 2021;  
BS EN IEC 61000-3-2: 2019;  
BS EN 61000-3-3: 2013+A1:2019**

The certificate of conformity is based on an evaluation of a sample of the above-mentioned product. Technical report and documentation are at the applicant's disposal. This is to certify that the tested sample is in conformity with Electromagnetic Compatibility Regulations 2016 by UK legislation (UK SI 2016 No. 1091). The certificate of conformity does not imply assessment of the production and does not permit the use of Lab's logo. The applicant is authorized to use this certificate in connection with UK Declaration of Conformity.



**Nov. 09, 2022**  
Date

Certified by

KingKong Jin



The UKCA mark may only be used if all relevant and effective UK Regulations are complied with



**Shenzhen Anbotek Compliance Laboratory Limited**

1/F, Building D, Sogood Science and Technology Park, Sanwei community, Hangcheng Street, Bao'an District, Shenzhen, Guangdong, China.518128  
Tel: (86)755-26066440 Fax: (86)755-26014772  
Http://www.anbotek.com Email: [service@anbotek.com](mailto:service@anbotek.com)



安博  
检测